

Rec'd PCT/PTO 22 DEC 2004 #2

REC'D 19 AUG 2003

WIPO PCT

P1 1050810

THE UNITED STATES OF AMERICA

~~TO ALL TO WHOM THESE PRESENTS SHALL COME:~~

UNITED STATES DEPARTMENT OF COMMERCE
United States Patent and Trademark Office

August 12, 2003

THIS IS TO CERTIFY THAT ANNEXED HERETO IS A TRUE COPY FROM
THE RECORDS OF THE UNITED STATES PATENT AND TRADEMARK
OFFICE OF THOSE PAPERS OF THE BELOW IDENTIFIED PATENT
APPLICATION THAT MET THE REQUIREMENTS TO BE GRANTED A
FILING DATE.

APPLICATION NUMBER: 60/467,719

FILING DATE: May 02, 2003

RELATED PCT APPLICATION NUMBER: PCT/US03/21194

By Authority of the
COMMISSIONER OF PATENTS AND TRADEMARKS



L. Edelen

L. EDELEN
Certifying Officer

BEST AVAILABLE COPY

PRIORITY DOCUMENT
SUBMITTED OR TRANSMITTED IN
COMPLIANCE WITH
RULE 17.1(a) OR (b)

05-05-03

60467719.050203

05/02/03



Practitioner's Docket No. 100325.0194PRO2

PATENT

IN THE UNITED STATES PATENT AND TRADEMARK OFFICE

In re application of: Satish Reddy, Jeffrey Scherffius and John Gilmartin

For: Improved Split Flow Process and Apparatus

Box Provisional Patent Application
Commissioner for Patents
PO Box 1450
Alexandria, VA 22313-1450



COVER SHEET FOR FILING PROVISIONAL APPLICATION
(37 C.F.R. § 1.51(c)(1))

This is a request for filing a PROVISIONAL APPLICATION FOR PATENT under 37 C.F.R. § 1.51(c)(1)(i). The following comprises the information required by 37 C.F.R. § 1.51(c)(1):

1. The following comprises the information required by 37 C.F.R. § 1.51(c)(1):
2. The names of the inventors are (37 C.F.R. § 1.51(c)(1)(ii)):
 1. Satish Reddy
 2. Jeffrey Scherffius
 3. John Gilmartin
3. Residence addresses of the inventors, as numbered above (37 C.F.R. § 1.51(c)(1)(iii)):
 1. 7 Falling Leaf
Irvine, CA 92708
 2. 1 Kara Ct.
Aliso Viejo, CA 92656
 3. 22501 Chase, # 5216
Aliso Viejo, CA 92656

EXPRESS MAILING UNDER 37 C.F.R. § 1.10*

Express Mail label number is mandatory
(Express Mail certification is optional)

I hereby certify that this paper, along with any document referred to, is being deposited with the United States Postal Service on this date May 2, 2003 in an envelope addressed to the Commissioner for Patents, Washington D.C. 20231 as "Express Mail Post Office to Addressee" Mailing Label No. EV193156875US.

Date: 5/2/03

Erika Simpson

4. The title of the invention is (37 C.F.R. § 1.51(c)(1)(iv)):

Improved Split Flow Process and Apparatus

5. The name, registration, customer and telephone numbers of the practitioner are (37 C.F.R. § 1.51(c)(1)(v)):

Name of practitioner: Martin Fessenmaier
Reg. No. 46697
Tel. 714-641-5100
Customer No. 34284

6. The docket number used to identify this application is (37 C.F.R. § 1.51(c)(1)(vi)):

Docket No. 100325.0194PRO2

7. The correspondence address for this application is (37 C.F.R. § 1.51(c)(1)(vii)):

Martin Fessenmaier
Rutan & Tucker LLP
611 Anton Blvd., Suite 1400
Costa Mesa, CA 92626

8. Statement as to whether invention was made by an agency of the U.S. Government or under contract with an agency of the U.S. Government. (37 C.F.R. § 1.51(c)(1)(viii)).

This invention was NOT made by an agency of the United States Government, or under contract with an agency of the United States Government.

9. Identification of documents accompanying this cover sheet:

A. Documents required by 37 C.F.R. § 1.51(c)(2)-(3):

Specification:	No. of pages	34
Drawings:	No. of sheets	0

B. Additional documents:

None

10. Fee

The filing fee for this provisional application, as set in 37 C.F.R. § 1.16(k), is \$160.00 for other than a small entity.

11. Fee payment

Fee payment in the amount of \$160.00 is being made at this time.


12. Method of fee payment

Check in the amount of \$160.00.

Please charge Account No. 502191 for any fee deficiency.

Date:

5/2/03



Martin Fessenmaier
Registration No. 46697
Rutan & Tucker
611 Anton Blvd., Suite 1400
Costa Mesa, CA 92626
714-641-5100
Customer No. 34284

Fluor's Econamine FG PlusSM Technology

An Enhanced Amine-Based CO₂ Capture Process

FLUOR[®]

Satish Reddy
Jeff Scherffius
Stefano Freguia
Fluor Enterprises, Inc.
Aliso Viejo, CA

Christopher Roberts
Fluor Ltd., UK
Camberley, UK

Presented At:
Second National Conference on Carbon Sequestration
National Energy Technology Laboratory/Department of Energy
Alexandria, VA
May 5-8, 2003

The Econamine FGSM and Econamine FG PlusSM technologies are Fluor proprietary amine-based carbon dioxide removal processes. All of the Econamine FGSM and Econamine FG PlusSM technology described in this paper is protected by existing or pending patents owned by Fluor.

satish.reddy@fluor.com

1 Fluor Daniel Drive
Aliso Viejo, CA 92656

phone: 949.349.4959
fax: 949.349.2898

May 2003

Background: Econamine FGSM Process

The Econamine FG PlusSM technology is an advanced version of Fluor's Econamine FGSM technology, which has been used in 23 commercial plants for the recovery of carbon dioxide from flue gas.

Econamine FGSM technology uses monoethanolamine (MEA) as the basis of its solvent. However, the solvent formulation is specially designed to recover CO₂ from low pressure, oxygen-containing streams, such as burner flue gas streams. Therefore, it is a post-combustion CO₂ capture system and is easy to retrofit to existing facilities. Recovery of carbon dioxide from combined cycle gas turbine and coal-fired power plants is a good candidate for this technology. Chemical and fertilizer plants requiring additional CO₂ as a feedstock can also benefit from CO₂ recovery using this technology.

Carbon dioxide capture can be used for the following applications:

- **CO₂ sequestration**
- **Enhanced oil recovery (EOR)**
- **Merchant CO₂ sales**
- **Chemical feedstock production**

Most alkanolamine systems cannot operate in a flue gas environment, because the amine will rapidly degrade in the presence of oxygen.¹ This is prevented in the Econamine FGSM solvent by the addition of a proprietary inhibitor. This inhibitor also protects the equipment against corrosion and allows for conventional materials of construction, mostly carbon steel.

The Econamine FGSM flowsheet is similar to a generic gas treating process, which has been practiced for many years. All equipment items and operations are simple, reliable, and generally familiar to operating personnel. A typical Econamine FGSM flowsheet is presented in Figure 1, for reference.




Figure 1: Typical Econamine FGSM Flowsheet

The Econamine FGSM process can be (and has been) safely located on a pressure sensitive CO₂ emitting source, such as a steam-methane reformer (SMR) flue gas line. At one facility in the USA, the Econamine



FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS

May 2003

FGSM plant is located on the exhaust duct of a gas turbine in a power plant, where neither a backpressure nor a pressure fluctuation can be tolerated. The technology is also located on reformer flue gas lines in India and Brazil. All of these plants consistently remove the carbon dioxide from the flue gas without disturbing the upstream pressure.

In order to avoid the formation of heat stable salts in the solution, SO_x, NO_x (specifically NO₂ and equivalent species), and particulates must be reduced to an acceptable level upstream of the Econamine FGSM absorber. This step can be incorporated into Fluor's total project solution for the Econamine FGSM or (Econamine FG PlusSM) CO₂ capture plant.

Commercial Plant Example: FPL Facility at Bellingham, MA

The Econamine FGSM technology has been successfully implemented at 23 commercial plants worldwide. One of these plants is a 360 STPD (327 Te/d) CO₂ recovery plant in the Florida Power and Light power plant in Bellingham, MA, USA. The Econamine FGSM plant was designed and constructed by Fluor, and has been in continuous operation since 1991.

This facility is the only commercial-scale CO₂ recovery unit in the world operating on gas turbine flue gas. This is notable for three reasons:

1. The CO₂ concentration in the flue gas is low, being only 2.8 to 3.1 vol%.
2. The oxygen concentration in the flue gas is high, being approximately 13 vol%.
3. Neither a backpressure nor a pressure fluctuation in the flue gas line can be tolerated.

The quality of the carbon dioxide product is suitable for use in the food and beverage industry. This is a better quality CO₂ than is needed for sequestration EOR.

Figure 2 shows an aerial view of the Bellingham Econamine FGSM plant. The plant design was based on air cooling only, hence the large bank of air coolers. The area shown in the picture also includes the CO₂ liquefaction, storage, and truck loading facilities. Figure 3 shows a ground level view of the absorber and stripper in the Bellingham facility.

Fluor has used the experienced gained at the Bellingham facility to develop in-house expertise on amine degradation and corrosion prevention strategies. In fact, Fluor is the only technology vendor with long term commercial operating experience with CO₂ recovery from flue gas with a very high oxygen concentration. This translates into a more reliable and cost effective design and operation of the Econamine FG PlusSM plant.

FLUOR®

**FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS**

May 2003




Figure 2: Bellingham Econamine FGSM Plant Aerial View




Figure 3: Bellingham Econamine FGSM Plant Ground View

Future of Carbon Dioxide Recovery Plants

Large-scale carbon dioxide sequestration projects are currently being planned. With absorber diameters of 40 to 50 feet considered feasible (Figure 4), CO₂ recovery plant capacities of up to 8,000 Te/d are achievable, depending on the inlet flue gas CO₂ concentration. Even larger plants can be realized by



**FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS**

May 2003

employing multiple absorbers sharing a common stripper. The Econamine FGSM (and Econamine FG PlusSM) technology can be applied today to these large-scale CO₂ capture plants.




Figure 4: The Saudi Aramco Econamine (DGA) Plant in Uthamaniyah, Saudi Arabia has an absorber (center-right) with a large diameter.

Econamine FG PlusSM Technology

Using the Econamine FGSM technology and experience as a starting point, Fluor has developed an improved process called Econamine FG PlusSM. The new technology targets a goal of further lowering the energy consumption of the process. The Econamine FG PlusSM process is now being commercially offered.

The Econamine FG PlusSM technology consists of several pieces, including the following features:

- Improved solvent formulation
- Split flow configuration
- Stripping with condensate flash steam
- Absorber Intercooling
- Integrated steam generation

The above list serves as a menu of options from which a customized plant design can be developed to satisfy the specific requirements and operating parameters of each CO₂ removal application. In this way, Fluor can develop an optimized solution that minimizes the energy consumption, rather than offering only a standard design that was originally optimized for a different plant with different operating conditions.

Improved Solvent Formulation

An important feature of the Econamine FG PlusSM process is a new solvent formulation. The predominant amine for the solvent remains MEA, but the new formulation has the following benefits:

- **Increased Reaction Rates:** This decreases the required packing volume in the absorber, allowing a smaller, less expensive absorber.

FLUOR®**FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS**

May 2003

- Higher Solvent Capacity for CO₂: Because the solvent is capable of carrying more CO₂, less solvent circulation is required. This includes a decreased solvent flow through the stripper, thereby reducing the reboiler steam requirement.

Of course, the solvent still contains the proprietary inhibitor, and retains the low amine degradation and low corrosion qualities of the original Econamine FGSM solvent.

Split Flow Configuration

Another feature of the Econamine FG PlusSM process is a modified split flow configuration. In this configuration, two parallel regeneration schemes are utilized: flash regeneration and steam stripping.

The first portion of the rich solvent is regenerated in the stripper. Steam stripping removes the most carbon dioxide from the solvent and therefore provides the leanest solution, called lean solvent. A reboiler, requiring an external source of heat, provides the necessary energy to the stripper. This portion of solvent regeneration is identical to the standard Econamine FGSM stripper configuration.

The second portion of rich solvent is preheated against the lean solvent stream and then regenerated by flashing in a flash drum. The flashed solution contains more carbon dioxide than the lean solvent produced in the stripper, and is called semi-lean solvent. However, it is made without any additional steam requirement; the energy required for regeneration is provided by recovering the heat remaining in the lean solvent stream after it leaves the stripper reboiler.

Since some of the solvent entering the absorber has a higher loading with the split flow configuration, a higher circulation rate is required to meet the same recovery specification. However, the steam requirement is decreased because only a portion of the rich stream is being stripped to the leanest solution with external heat. As such, the split flow configuration decreases the energy consumption for the Econamine FG PlusSM process.

It should be noted that the increase in solvent circulation rate that results from the split flow configuration can be substantially mitigated by the implementation of the other Econamine FG PlusSM process features. As such, the overall solvent circulation rate of a complete Econamine FG PlusSM plant is only slightly higher than that of a standard Econamine FGSM plant.

Stripping with Condensate Flash Steam

This portion of the Econamine FG PlusSM technology is an extension of the split flow process. In order to decrease the partial pressure of the carbon dioxide above the semi-lean solvent in the flash drum, thereby decreasing the semi-lean solvent loading, steam is added to the flash drum. However, in order to avoid an increase in overall steam consumption, this steam is extracted from the saturated reboiler steam condensate by flashing the condensate at the semi-lean flash pressure. Hence, no additional steam is required.

The addition of steam to the semi-lean flash drum reduces the semi-lean loading, thereby decreasing the overall solvent circulation rate. The end effect is a decrease in the reboiler energy requirement.

Absorber Intercooling

Absorber intercooling is used to reduce the temperature in the middle of the absorber packed beds, as illustrated in Figure 5.

FLUOR®

**FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS**

May 2003




Figure 5: Absorber Temperature Profile with Intercooling

The intercooling has two major effects. First, the overall absorption rate of CO₂ is increased, decreasing the absorber size and capital cost.

Secondly, the rich solvent loading is increased, thereby decreasing the solvent circulation rate. The higher rich loading and the decreased solvent circulation rate both result in a decreased energy requirement in the stripper reboiler.

In a simple two-bed absorber, the cooling is accomplished by extracting the semi-rich solvent from the top (trim) bed of the absorber, cooling this solvent, and returning it to the bottom (bulk) bed of the absorber. If the absorber has more than two beds, then additional intercooling steps can be added.

If the process is a split flow configuration, the semi-rich solvent can be mixed with the semi-lean solvent prior to cooling. Alternatively, only the semi-lean solvent can be cooled without extracting the semi-rich solvent from the absorber. The intercooling philosophy depends on the Econamine FG PlusSM overall configuration and the specific operating parameters of the plant.

Integrated Steam Generation

Another way the Econamine FG PlusSM technology can save capital and operating costs is by integrating a steam generation system into the process (Figure 6). All of the Econamine FG PlusSM steam requirements can be met by such a system. This option is especially attractive when the Econamine FG PlusSM unit is added to the CO₂ producing plant as a retrofit and a new, dedicated steam generation unit is required.

FLUOR

**FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS**

May 2003




Figure 6: Integrated Steam Generation Econamine FG PlusSM Plant

There are two primary methods for generating the required steam:

1. If the flue gas temperature is high enough, the steam can be raised from heat recovery alone. Doing so not only generates steam, but it also decreases the load on the direct contact cooler. This scheme is potentially applicable to open cycle gas turbine power plants, furnaces, fired heaters, and any other process that produces a very high temperature flue gas.
2. In some cases, duct firing can be done in the flue gas upstream of the main Econamine FG PlusSM plant to generate heat, from which steam can be raised. This is done when the flue gas temperature is too low or the flue gas mass flow (i.e. heat flow) is too low to meet the steam requirement.

The duct-firing of the flue gas has the added advantage of increasing the CO₂ concentration in the absorber feed gas, thereby reducing the necessary removal rate of the Econamine FG PlusSM plant if a fixed quantity of CO₂ recovery is desired. If, instead, the CO₂ emission rate is fixed, then the recovery of the supplemental CO₂ is easier due to the higher gas concentration and the fact that a CO₂ recovery facility is already available on that stream. If the steam were raised in a separate boiler, boiler flue gas ducting and an additional blower would be required to route the flue gas to the Econamine FG PlusSM unit.




Figure 7: Integrated Steam & Power Generation Econamine FG PlusSM Plant



**FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS**

May 2003

Another option is to raise superheated high pressure steam that can first be used for power generation prior to being used as utility steam (Figure 7). This power could be used for the plant's pumps and blower or exported to other parts of the parent facility.

Benefits of Econamine FG PlusSM Technology

In addition to the added energy savings of the Econamine FG PlusSM technology, all of the benefits of the original Econamine FGSM remain. These benefits include:

- Fluor's Econamine FG PlusSM process is specially designed for removing carbon dioxide from low-pressure, oxygen-containing flue gas streams.
- The plant can be built with conventional materials of construction. The majority of the plant is constructed from carbon steel. Where the potential for corrosion is highest, stainless steel (usually 304SS) is used.
- The Econamine FG PlusSM technology does not require a custom-manufactured or expensive "boutique" solvent. The MEA solvent is readily available and inexpensive. In fact, it is the lowest cost amine available. MEA is produced by solvent manufacturers worldwide.
- The Econamine FG PlusSM process has the lowest heat requirement and the lowest solvent circulation rate (for a given configuration) versus all competing MEA-based processes.
- The Econamine FGSM technology has been successfully demonstrated in commercial applications with more than 20 plants licensed over the past 20 years. In this time, Fluor has further improved the process configuration to lower the energy consumption.

Heat Integration with the Carbon Dioxide Producing Process

Another method of achieving substantial energy savings is by comprehensive heat integration with the process that is producing the CO₂. In this way, heat can be exchanged between process streams, thereby reducing the utility cooling water and steam demands.

Heat integration with power plants and refinery or petrochemical processing plants is feasible. In particular, heat integration with a power plant shows a good synergy. The Econamine FG PlusSM process-cooling can be accomplished by using vacuum condensate as the cooling source. In this way, the cooling water or air cooling load is minimized, and the heat is productively recovered by the vacuum condensate instead of wasted to a utility stream. Examples of suitable process coolers include the stripper overhead condenser, lean amine cooler, and semi-lean amine cooler.

Comparison of Econamine FG PlusSM Technology with Other Amine Scrubbing Options

The Econamine FGSM technology has been successfully demonstrated in over 20 commercial plants, including:

- The only CO₂ absorption plant anywhere in the world that recovers CO₂ at a commercial-scale from gas turbine flue gas
- A 1,000 Te/d (1,100 STPD) CO₂ recovery plant (for EOR)



**FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS**

May 2003

ABB Lummus Crest, using Kerr McGee Technology, has three commercial plants using and MEA based solvent.² However, its solvent strength is low compared to the Econamine FG PlusSM solvent strength. Because of this, the ABB Lummus Crest plants require both a higher circulation rate and higher reboiler duty than the base Econamine FGSM process and much more than the Econamine FG PlusSM process.

MHI/KEPCO have developed a process that uses a proprietary hindered amine known as KS-1. Only one commercial plant has been built.³ The solvent cost is approximately 5 times the cost of MEA^{4,5} (nearly 4.5 times the cost of Econamine FG PlusSM solvent). Although MHI claims that its solvent losses are much less than those of Econamine FG PlusSM, the annual cost of solvent replacement is approximately the same.

Case Study: Comparison of Econamine FG PlusSM to KS-1

MHI has published papers on the performance of its KS-1 solvent in the Petronas Fertilizer Co. CO₂ capture plant in Malaysia.^{3,6} This is the only commercial installation of KS-1. Using this data, the performance of the Econamine FG PlusSM technology can be compared to KS-1.

The flue gas conditions are listed in Table 1. The gas source is flue gas from a steam reformer.

Table 1: Petronas Fertilizer Co. Reformer Flue Gas Conditions

Flow Rate	47,000 Nm ³ /h
Temperature	168 °C
Composition	
N ₂	67.79 % (v/v)
CO ₂	8.08 % (v/v)
O ₂	0.85 % (v/v)
Ar	1.00 % (v/v)
H ₂ O	22.28 % (v/v)
SO _x	2.44 ppm
NO _x	200 ppm

The plant recovers 90% of the carbon dioxide for a total product rate of 160 Te/d. The product has a dry purity of over 99.9 vol% CO₂ and its pressure is 0.55 bar-g.

Table 2 shows the energy consumption and amine cost for the two processes.

FLUOR

FLUOR'S ECONAMINE FG PLUSSM
TECHNOLOGY: AN ENHANCED
AMINE-BASED CO₂ CAPTURE PROCESS

May 2003

Table 2: Comparison of Econamine FG PlusSM and KS-1

	Units	Econamine FG Plus SM	KS-1
Energy Consumption	Btu/lb CO ₂	1395	1376
Solvent Replacement Cost	US\$/Te CO ₂	2.30	2.28

As seen in the table, the Econamine FG PlusSM technology requires virtually the same energy that MHI's KS-1 solvent. This is a significant improvement compared with the original Econamine FG PlusSM process energy requirement.

In addition, the solvent replacement costs are nearly identical. This is because although the KS-1 solvent loss is roughly 4.3 times less than that for Econamine FG PlusSM, the cost of KS-1 is 4.3 times more expensive than Econamine FG PlusSM solvent (MEA plus inhibitor).^{4,5}

These results show that the Econamine FG PlusSM process is very competitive with KS-1. In addition, the experience of twenty years of operation and 23 commercial plants make Econamine FG PlusSM a very attractive solution for flue gas CO₂ recovery.

Summary

The Econamine FG PlusSM process is an efficient, cost effective, and simple process for the removal of CO₂ from low-pressure, oxygen-containing flue gas streams. In developing the technology, Fluor has reduced the energy consumption below that of the original Econamine FGSM process, which was already the most efficient MEA-based process available. The Econamine FG PlusSM technology consists of several process features that can be assembled in many different combinations in order to provide a custom-fit solution to each carbon dioxide recovery application. When combined with heat integration with the parent CO₂ producing plant, additional substantial energy savings can be realized.

References


- ¹ Kohl, A. L., and R. B. Nielsen, *Gas Purification*, 5th Ed., Gulf Publishing Company, 1997.
- ² Barchas, R. and R. Davis, "The Kerr-McGee/Lummus Crest Technology for the Recovery of CO₂ from Stack Gases," First International Conference on Carbon Dioxide Removal, Amsterdam, The Netherlands, March 4-6, 1992.
- ³ Mimura, T., K. Matsumoto, M. Iijima, and S. Mitsuoka, "Development and Application of Flue Gas Carbon Dioxide Recovery Technology," Fifth International Conference on Greenhouse Gas Control Technologies, Cairns, Australia, August 13-16, 2000.
- ⁴ Mitsubishi Heavy Industries, Ltd., "Flue Gas CO₂ Capture (CO₂ Capture Technology of KS-1)," International Test Network for CO₂ Capture 4th Workshop, Kyoto, Japan, October, 2002.
- ⁵ *Chemical Market Reporter*, April 7, 2003.
- ⁶ Mitsubishi Heavy Industries, Ltd., "Flue Gas CO₂ Recovery Unit," *Japanese Advanced Environment Equipment*, Japan Society of Industrial Machinery Manufacturers, 2001.

Fluor's Econamine FG PlusSM Technology

An Enhanced Amine-Based CO₂ Capture Process

NETL Carbon
Sequestration
Conference

May 2003



FLUOR[®]

60457719 .050203

Presentation Outline

- ◆ Econamine FGSM Technology
- ◆ Econamine FG PlusSM Technology Features
- ◆ Heat Integration with the CO₂ Producing Process
- ◆ Comparison to other Amine Scrubbing Technologies

FLUOR®

60467719 .05020

Patent Disclosure

- ◆ The following technologies, described in this presentation, are protected by existing or pending patents owned by Fluor
 - Econamine FGSM
 - Econamine FG PlusSM (all components)
 - Heat integration with a power plant or process facility
- ◆ Additional details of the process can be made available after a secrecy agreement has been signed

FLUOR[®]

050500 . 19 746705


Econamine FGSM Process

- ◆ CO₂ capture via monoethanolamine (MEA) solution with proprietary inhibitor
- ◆ Technology permits the economical extraction of CO₂ from oxygen-containing streams, such as flue gas
- ◆ Post combustion CO₂ capture system
 - Applicable to existing facilities
 - CCGT and coal fired power plants are candidates
- ◆ SO_x, NO_x, and particulates must be removed upstream
 - Part of Fluor's total project solution
- ◆ Large scale CO₂ recovery plants are possible
 - 40 to 50 ft diameter absorbers are considered feasible
 - CO₂ recovery up to 8,000 Te/d per absorber

FLUOR®

60467719 . 05021

Example of Large Diameter Absorber



- ◆ Fluor-built Saudi Aramco Econamine (DGA) Plant
 - Uthamaniyah, Saudi Arabia


FLUOR®

Econamine FGSM Features

- ◆ Econamine FGSM inhibitor protects the amine and the equipment
 - Allows CO₂ removal from oxygen-containing streams by preventing amine degradation
 - Allows conventional materials of construction, mostly carbon steel, by preventing corrosion
- ◆ Similar to generic gas treating processes employed for many years
 - Only simple, reliable equipment used in the process

FLUOR®

Econamine FGSM Basic Flowsheet



FLUOR[®]

60467719, 050203

Commercial Plant Example: FPL Facility at Bellingham, MA

- ◆ The only commercial-scale CO₂ recovery unit in the world operating on gas turbine flue gas
 - Only 2.8 - 3.1 vol% CO₂ in flue gas
 - Over 13 vol% O₂ in flue gas
- ◆ Recovery is 360 STPD (327 Te/d) of carbon dioxide
- ◆ Continuously operating since 1991
- ◆ Produces carbon dioxide product suitable for use in the food & beverage industry
 - Better quality than needed for CO₂ sequestration
- ◆ Designed and constructed by Fluor
 - Used by Fluor to develop know-how on amine degradation and corrosion prevention strategies

FLUOR®


Bellingham Plant Aerial View



FLUOR®

60467719.050203

Bellingham Plant Ground View



Strip

Reclaim

ber

DCC

er

FLUOR®

60467719.05020

Econamine FG PlusSM Features

- ◆ Fluor has developed an improved Econamine FGSM process, called Econamine FG PlusSM
- ◆ Process designed for lower energy consumption
- ◆ Econamine FG PlusSM process enhancements include:
 - Improved solvent formulation
 - Split flow configuration
 - Stripping with condensate flash steam
 - Absorber intercooling
 - Integrated steam generation
- ◆ Plant specifics dictate which features are included, thereby creating a customized and optimized facility

FLUOR®

New Solvent Formulation

- ◆ Remains MEA-based
- ◆ Increased reaction rates
 - Decreased absorber size
- ◆ Higher solvent capacity for CO₂
 - Lower circulation rate than standard Econamine FGSM solvent
 - Lower energy demand for regeneration

FLUOR®

Split Flow Configuration

- ◆ Rich solvent split into two streams for parallel regeneration
 - One stream fed to stripper to generate lean solvent
 - Used for trim absorption in the top absorber bed
 - Second stream by-passes stripper and is preheated against process streams and flashed to generate semi-lean solvent
 - Used for bulk absorption in the bottom absorber bed
- ◆ Total circulation rate increases, but less energy is required
 - Increase in solvent rate is substantially mitigated with the implementation of the reformulated solvent

FLUOR®

Stripping with Condensate Flash Steam

- ◆ Steam condensate (saturated) from the reboiler is let down to semi-lean flash drum pressure
- ◆ Condensate flash vapor (i.e. steam) is injected into the semi-lean flash drum as stripping medium, reducing semi-lean loading
- ◆ Requires lower circulation rate than split flow configuration alone
- ◆ Reboiler duty is further reduced

FLUOR®

60467719 .050203


Absorber Intercooling

- ◆ Semi-rich solvent flowing from the top (trim) bed is extracted from the column and is mixed with semi-lean solvent and cooled
- ◆ Cooled solvent is returned to the bottom (bulk) bed of the absorber
- ◆ Lower temperature increases the absorption rate
 - Decreased absorber size
- ◆ Increases rich solvent loading
 - Decreases circulation rate
 - Reduces energy requirement
- ◆ If the absorber has more than two beds, then additional intercooling steps can be added

FLUOR®

Absorber Temperature Profile With Intercooling

Top of Packing
(Lean Inlet)



Bottom of Packing
(Rich Outlet)

Liquid Temperature

FLUOR®

60467719.050203

Integrated Steam Generation

- ◆ Flue gas can be used to generate all steam requirements for the Econamine FG PlusSM plant
- ◆ If flue gas temperature is high, steam can be raised from heat recovery alone
- ◆ In addition, duct firing can be employed to raise additional steam
 - Added benefit of increasing CO₂ concentration to absorber
- ◆ Option: generate power by raising high-pressure steam

FLUOR®

Econamine FG PlusSM Benefits

- ◆ Low cost carbon steel materials of construction used for most equipment items
- ◆ MEA is the lowest cost amine and is readily available world-wide

— Annual inhibitor cost adds only approximately 20% to the MEA cost

- ◆ Lowest heat requirement for competing MEA-based processes
- ◆ Lowest solvent circulation rate for competing MEA-based processes

FLUOR[®]

Heat Integration with CO₂ Producing Process

- ◆ Heat integration with power/refinery/petrochemical process units is feasible
- ◆ Excellent integration opportunity with a power plant
 - Econamine FG PlusSM process cooling can be carried out with vacuum condensate
 - Stripper overhead condenser and absorber coolers provide heat to steam turbine vacuum condensate
 - Minimize steam and cooling water consumption
 - Substantial energy savings

FLUOR®

Amine Scrubbing Experience

- ◆ Fluor Econamine FGSM & Econamine FG PlusSM
 - Relatively high MEA concentration in solvent
 - Allows for reduced circulation rate and reboiler duty
 - 23 commercial plants, including:
 - Only commercial-scale CO₂ absorption plant on gas turbine flue gas
 - 1,000 Te/d CO₂ recovery plant for EOR
- ◆ ABB Lummus; Kerr McGee Technology
 - Lower MEA concentration than Econamine FG PlusSM
 - 3 commercial plants
- ◆ MHI/KEPCO
 - KS-1 hindered amine solvent
 - 1 commercial plant

FLUOR®

60467749 . 05080

Case Study: Comparison of Econamine FG PlusSM to MHI/KEPCO KS-1

- ◆ Basis is flue gas from Petronas Fertilizer Co. CO₂ capture plant in Malaysia
 - Only KS-1 commercial installation
 - MHI has published papers on its performance
- ◆ Flue gas source is steam reformer
 - 10.4 vol% (dry) CO₂
 - 1.1 vol% (dry) O₂
- ◆ CO₂ recovery is 160 Te/d
 - 90% recovery of incoming CO₂

FLUOR[®]

Comparison of Econamine FG PlusSM to MHI/KEPCO KS-1

	Units	Econamine FG Plus SM	KS-1
Reboiler Steam Consumption	Btu/lb CO ₂	1395	1376
Solvent Replacement Cost	US\$/Te CO ₂	2.30	2.28

- ◆ Steam consumption is within 1.5% of each other
- ◆ Solvent replacement costs are nearly identical
 - KS-1 reported solvent loss is nearly 4.3 times less than Econamine FG PlusSM
 - **BUT** KS-1 purchase price is approximately 4.3 times more than Econamine FG PlusSM

Summary

- ◆ The Econamine FG PlusSM process has reduced energy consumption
- ◆ If integrated with power/refinery/petrochemical process units, there can be further considerable saving in energy
- ◆ Econamine FG PlusSM technology allows CO₂ removal with low capital cost, low energy consumption and simple equipment

FLUOR®

**This Page is Inserted by IFW Indexing and Scanning
Operations and is not part of the Official Record**

BEST AVAILABLE IMAGES

Defective images within this document are accurate representations of the original documents submitted by the applicant.

Defects in the images include but are not limited to the items checked:

☒ **BLACK BORDERS**

☐ **IMAGE CUT OFF AT TOP, BOTTOM OR SIDES**

☐ **FADED TEXT OR DRAWING**

☒ **BLURRED OR ILLEGIBLE TEXT OR DRAWING**

☐ **SKEWED/SLANTED IMAGES**

☐ **COLOR OR BLACK AND WHITE PHOTOGRAPHS**

☐ **GRAY SCALE DOCUMENTS**

☐ **LINES OR MARKS ON ORIGINAL DOCUMENT**

☐ **REFERENCE(S) OR EXHIBIT(S) SUBMITTED ARE POOR QUALITY**

☐ **OTHER:** _____

IMAGES ARE BEST AVAILABLE COPY.

As rescanning these documents will not correct the image problems checked, please do not report these problems to the IFW Image Problem Mailbox.